

Winter Preparedness Test – Dual Fuel Fall Test

The Winter Preparedness Test for Interruptible Heat (Dual Fuel) Members is scheduled for the **Wednesday before Thanksgiving each year**. This load control test is performed in advance of the winter Full Load Control season to ensure member familiarity with the control sequence and to ensure that backup heating systems have been validated for proper function. During the test, residential Interruptible (Dual Fuel) Heat load classes (2A, 2B, 2C, 2W, & 4B) will be controlled as follows:

Time	Control Status
5:00 pm	Control start
5:30 pm	All loads interrupted (2A,2B,2C,2W,4B)
8:30 pm	Class 4B loads restored
9:30 pm	Class 2B loads restored
10:00 pm	Class 2A loads begin diversified restoral
10:40 pm	Class 2C loads begin diversified restoral
11:00 pm	Class 2A, 2C, 2W loads restored

Control status is viewable at http://xso.dairylandpower.coop/lm/LCstatus_xres.html
Thank you for your attention and efforts toward making this a successful test. Please contact us with any questions. Call Ron @ 800-236-2141 ext 563

=====

LOAD MANAGEMENT COMMUNICATIONS PROCEDURES

Options for obtaining additional load control information from DPC

1. During normal business hours 7:30am - 4:30pm:
(800) 356-8305 Ask for extension 360 or 433.
2. Load Management Recording after or during normal business hours (updated on an needed basis):
Message Recording (800) 784-9960
Dial 0 at tone to forward to staff. (Touch Tone phone required).
3. On Call cell phone (608) 386-8946 after hours and weekends for critical Load Management questions.

3200 East Ave S - P.O. Box 817 - La Crosse, WI 54602-0817