

Right-Of-Way Width Specifications

Scenic River Energy Cooperative's (SREC) **Rural** right-of-way widths are 20 feet from the nearest conductor (both single and multiphase lines), measured perpendicularly from the centerline of the nearest conductor outward 20 feet in both directions.

SREC's **Urban** right-of-way widths are 15 feet from the nearest conductor (both single and multiphase lines), measured perpendicularly from the centerline of the nearest conductor outward 15 feet in both directions. Exceptions to the above, as designated by the authorized SREC representative.

The following guidelines have been established for SREC's right-of-way program:

Definition of Right-of-Way Location:

Rural: Defined as any primary lines not within a maintained lawn area near approved lakeshore, dwelling, or business including the primary maintained driveway entrance.

Urban: Defined as any primary lines within* a maintained lawn area near approved lakeshore, dwelling, or business *excluding* the primary maintained driveway entrance.

- Only if line is the same side of public road as buildings and it is the same property owner. Cover only the area under the line that is the frontage of the maintained yard area. Not meant to include areas other than parallel to a lakeshore, dwelling, or business.
- Right-of-way on which past vegetation maintenance practices have established *wider limits* shall be maintained to the full extent of the previously maintained width.
- The Contractor shall designate the edges of the desired right-of-way with flagging or other acceptable marking, as required, to maintain a uniform width as specified by the contract documents, attachments, or authorized SREC representative.
- ***Pine Plantations*** or tree/trees that had been planted by a landowner shall be considered as an Urban definition.
- Underground right-of-way is 10' on either side of the line.

Please see **next page (Appendix 8.1)** for the drawings of both the rural and urban line clearance specifications:

Appendix 8.1: Right-of-Way Clearing Guide

